



NOTES:

- 1 - GROUNDING CONDUCTOR SHALL BE ATTACHED TO GROUND LUG INSIDE METER BASE.
- 2 - INUSE COVERS ON ALL OUTLETS.

Item No.	Material	Qty.	Item No.	Material	Qty.
1	1 ϕ , 200A METER BASE	1	6	6"x 6"x8' TREATED WOOD POST	2
2	WEATHERPROOF BREAKER BOX	1	7	2"x 6" TREATED WOOD PLANK	As Req'd.
3	2-1/2", SCH. 80 PVC CONDUIT	As Req'd.	8	GROUND ROD, 5/8"x 8' COPPERWELD	1
4	2-1/2" CONDUIT CLAMP	2	9	CONDUCTOR, #4 BARE COPPER	As Req'd.
5	2-1/2" SCH. 80 36"R PVC SWEEP	1			

FILE: SK84.DWG

BY: CKD

DATE: 02/11/08



1 ϕ RV
PERMANENT UNDERGROUND
METER ASSEMBLY

STANDARD
DETAIL

SK-84