



NOTES:

1 - BOX MUST BE EQUIPPED WITH PROVISION FOR ADDITIONAL BRANCH CIRCUIT FEEDS FOR FUTURE USE.

Item No.	Material	Qty.
1	SERVICE POLE, 18'-0" LENGTH, 6" THICKNESS (or class 6 if round)	1
2	2" ALUMINUM CONDUIT CLAMP	As Req'd.
3	2" SCH. 80 PVC CONDUIT	3
4	1φ, 200 A METER BASE, ANCHOR CAT. NO. URS1904-G-HO	1
5	200 A, 240 V, BREAKER CABINET	1
6	#4 COPPER GROUND WIRE (AS REQUIRED)	As Req'd.
7	APPROVED ACORN GROUND ROD CLAMP	1
8	GROUND ROD, 5/8" X 8' COPPERWELD	1



1φ MOBILE HOME
METER POLE INSTALLATION

BY: CKD

DATE: 11/15/01

STANDARD
DETAIL

SK-78